



Certificate of Conformity

Customer: DEHN + SÖHNE GmbH + Co.KG.
Hans-Dehn-Str. 1
92318 Neumarkt i.d. OPf.
Germany

Product designation: Surge arrester for rated voltages up to 51 kV

Type: DMI (3...51) 10 1 L
DMI (3...51) 10 1 N
DMI (3...51) 10 1 H

Type Test report:

Tests performed	Report No.	Clause	Issued on
Insulation withstand test	TR-E 09005IW	10.8.2	30.09.2009
Residual voltage test	TR-E 09005RS	8.3	19.08.2009
Long duration current impulse test	TR-E 09005LD	10.8.4	21.08.2009
Operation duty test	TR-E 09005OD	10.8.5	21.08.2009
Short circuit test	TR-E 09005SC	8.7	02.10.2009
Internal partial discharge test	TR-E 09005PD	8.8	30.09.2009
Bending moment test	TR-E 09005BM	10.8.9	03.10.2009
Environmental test	TR-E 09005EV	not demanded	02.10.2009
Weather ageing test	TR-E 09005WA	10.8.14	06.10.2009
TOV	TR-E 09005TO	Annex D	26.08.2009

The above mentioned product(s) fulfils the requirements of the following standards/specifications.

IEC-Standards:

- IEC 60099-4 Edition 2.2 (2009-05)
Surge arresters – Part 4: Metal-oxide surge arresters without gaps for a.c. systems

Issuer: Product Management

Place, Date: Neumarkt, January 26, 2016

DEHN + SÖHNE GmbH + Co. KG.
NEUMARKT/OPF. HANS-DEHN-STR. 1

Signatures: i.V. Lothar Gmelch