

# CERTIFICATE

## (1) EC-Type Examination

(2) **Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/EC**

(3) EC-Type Examination Certificate Number: **DEKRA 11ATEX0146 X** Issue Number: **3**

(4) Equipment: **Isolating Spark Gap series EXFS**

(5) Manufacturer: **DEHN + SÖHNE GmbH + Co. KG.**

(6) Address: **Hans-Dehn-Strasse 1, D-92318 Neumarkt / Opf., Germany**

(7) This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., notified body number 0344 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the directive.

The examination and test results are recorded in confidential test report number NL/DEK/ExTR11.0066/02.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 60079-0 : 2012 + A11**

**EN 60079-15 : 2010**

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment according to the Directive 94/9/EC. Further requirements of the directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the equipment shall include the following:



**II 3 G Ex nC IIC T4 Gc**

This certificate is issued on 23 August 2015 and, as far as applicable, shall be revised before the date of cessation of presumption of conformity of (one of) the standards mentioned above as communicated in the Official Journal of the European Union.

DEKRA Certification B.V.

R. Schuller  
Certification Manager

Page 1/2



© Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

(13) **SCHEDULE**

(14) **to EC-Type Examination Certificate DEKRA 11ATEX0146 X**

Issue No. **3**

(15) **Description**

The Isolating Spark Gap Types EXFS L 100 (923 060), EXFS L 200 (923 061), EXFS L 300 (923 062), EXFS L ... (special lengths), EXFS KU (923 019) and EXFS KU SN... (special lengths) are used for indirect connection / earthing of functionally isolated conductive system parts in potentially explosive gas atmospheres.

Ambient temperature range -20 °C to +60 °C.

**Electrical data**

Rated Power frequency withstand voltage (50 Hz) : U = 300 V;  
impulse sparkover voltage (1,2/50 µs) : U ≤ 2,5 kV;  
Lightning impulse current (10/350 µs) : I = 50 kA.

**Installation instructions**

The instructions provided with the equipment shall be followed in detail to assure safe operation.

(16) **Test Report**

No. NL/DEK/ExTR11.0066/02.

(17) **Special conditions for safe use**

For ambient temperature range, see (15).

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at (9).

(19) **Test documentation**

As listed in Test Report NL/DEK/ExTR11.0066/02.