



Certificate of Compliance

Certificate: 2479911

Master Contract: 215727

Project: 70176936

Date Issued: March 9, 2018

Issued to: Dehn & Sohne GmbH & Co. KG
Hans Dehn Strasse 1
NEUMARKT/OBERPFALZ, 92318
Germany
Attention: Mr. Christian Frey

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



A Yeung Peng
Issued by: A. Yeung, P. Eng.

PRODUCTS

CLASS 4873 82 - TELECOMMUNICATION EQUIPMENT - Protective Devices - Certified to US Standards

CLASS 4873 02 - TELECOMMUNICATION EQUIPMENT - Secondary Protectors Used In Telecommunication Networks

Component protectors DPA, UGKF, DGA with suffixes, and for use in data communication and fire alarm circuit. Details as shown below:

Model	Type	Part No.	Voltage Breakdown (100 V/s)		Impulse Voltage (100 V/us)
			L-L	L-G	
DEHNpatch	M CLE RJ45B 48	929 121	53-64	70-110	<1000
DEHNpatch	DPA CLE IP66	929 221	10-16	70-110	<1000
DEHNgate	BNC VCD	909 710	-	7-11	<1000
DEHNgate	BNC VCID	909 711	-	7-11	<1000
*UGKF	BNC	929 010	-	9-15	<1000



Certificate: 2479911

Master Contract: 215727

Project: 70176936

Date Issued: March 9, 2018

APPLICABLE REQUIREMENTS

- | | | | |
|-------------------|--------|---|---|
| CAN/CSA-C22.2 No. | 226-92 | - | Protectors in Telecommunication Networks |
| UL Std No. | 497B | - | Protectors for Data Communication and Fire Alarm Circuits |