



Certificate of Compliance

Certificate: 2733514

Master Contract: 215727

Project: 2733514

Date Issued: June 17, 2014

Issued to: Dehn & Sohne GmbH & Co. KG
Hans Dehn Strasse 1
NEUMARKT/OBERPFALZ, 92318
Germany
Attention: Mr. Christian Frey

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



A handwritten signature in black ink that reads 'A. Yeung P. Eng.'.

Issued by: A. Yeung, P. Eng.

PRODUCTS

CLASS 4873 82 - TELECOMMUNICATION EQUIPMENT - Protective Devices - Certified to US Standards

CLASS 4873 02 - TELECOMMUNICATION EQUIPMENT - Secondary Protectors Used In Telecommunication Networks

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.	226-92	-	Protectors in Telecommunication Networks
UL Std No.	497B	-	Protectors for Data Communication and Fire Alarm Circuits



Certificate: 2733514

Master Contract: 215727

Project: 2733514

Date Issued: June 17, 2014

CLASS 4873 02 - SECONDARY PROTECTORS USED IN TELECOMMUNICATION NETWORKS
CLASS 4873 82 - SECONDARY PROTECTORS USED IN TELECOMMUNICATION NETWORKS -
CERTIFIED TO U.S. STANDARDS

Component protectors Isolated Loop Circuit secondary Protectors, Din-Rail Mount Type, DCO SD2 Series:

Model	Part No.	Voltage Breakdown (100 V/s)		Impulse Voltage (100 V/us)
		L-L	L-G	
DCO SD2 ME 12	917 920	-	16-22	<1000
DCO SD2 ME 24	917 921	-	37-52	<1000
DCO SD2 ME 48	917 922	-	64-90	<1000
DCO SD2 MD 12	917 940	16-22	-	<1000
DCO SD2 MD 24	917 941	37-52	-	<1000
DCO SD2 MD 48	917 942	64-90	-	<1000
DCO SD2 MD EX 24	917 960	37-52	-	<1000
DCO SD2 MD HF 5	917 970	10-13	-	<1000
DCO SD2 E 12	917 987	-	14-20	<1000
DCO SD2 E 24	917 988	-	31-44	<1000
DCO SD2 E 48	917 989	-	64-90	<1000

Notes:

- 1. These devices are only to be used in ordinary, indoor location on isolated data loop circuits which are isolated from the public switched telephone network and not intended for any telephone loop circuits.**
- 2. Proper grounding continuity should be provided.**
- 3. Din Rail should be provided for mounting purposes.**



Supplement to Certificate of Compliance

Certificate: 2733514

Master Contract: 215727

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
2733514	June 17, 2014	Original Certification.