



# Certificate of Compliance

**Certificate:** 2391416

**Master Contract:** 215727 (215727)

**Project:** 70176838

**Date Issued:** 2018-03-09

**Issued to:** DEHN + SOEHNE GmbH & Co.KG.  
NEUMARKT/OBERPFALZ, 92318  
GERMANY

**Attention:** Christian Frey

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicator ▲*



**Issued by:** *Silby John*  
Silby John

## **PRODUCTS**

CLASS - C221331 - SURGE PROTECTIVE DEVICES-Components and Subassemblies-

Component assembly Surge Protective Devices (SPDs) modules, Type 4-2, "DEHNbloc Maxi/ M" series, Current carrying type:

Model No.	Rated Voltage (V ac)	MCOV (V ac)	Phase	Rated Current (A)	Rated Ambient Temp (°C)	Mode	Measured Limiting Voltage (MLV) (Vpk)	Nominal Discharge Current (I <sub>n</sub> )	Short Circuit Current Rating (SCCR (kA))
<b>PART A: DEHNbloc M series</b>									
961 110, 961 115	120	150	1	115	-40 - 85	L-N	1162	20	25
<b>PART B: DEHNbloc Maxi series</b>									
961 140, 961 145	347	440	1	115	-40 - 85	L-N	1539	20	25
961 175	600	760	1	115	-40 - 85	L-G	2715	20	10



**Certificate:** 2391416  
**Project:** 70176838

**Master Contract:** 215727  
**Date Issued:** 2018-03-09

---

Note:

- (1) The above models are certified only for use as components of other certified assemblies where the suitability of the combination is determined by CSA Group at the end use equipment.
- (2) The Measured MLV values shown above are for reference only.
- (3) Phase -1 = Single Phase
- (4) The Complete Assembly models in part A consist of:  
Base module 961 110 and plug-in module 961 001;  
Base module 961 115 and plug-in module 961 001.
- (5) Assemblies in part B are one piece construction, no separate plug-in modules.

**APPLICABLE REQUIREMENTS**

CSA C22.2No. 269.4-17 - Surge Protective Devices – Type 4 Component Assemblies